



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001




No F 6 / DFS / MS / 2025 / School / WZ / 882

Dated: 11/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Montfort School** located at **Ashok Vihar, Phase-1, Delhi-110052** comprised of **04 Blocks (02 Blocks- Ground plus three upper floors each, 01 Block- Ground plus two upper floors, all three blocks interconnected & 01 New Block- Ground plus three upper floors)** was issued FSC by this department vide letter No F6/DFS/MS/School/WZ/2022/511 dated 12.05.2022. The premise was re-inspected by the officer concerned of this department on 05.06.2025 in the presence of **Brother Joy Thomas (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirement under rule 33 of the Delhi Fire Service Rule, 2010 and that the building/ premise is fit for occupancy **Group B Educational** with effect from **11/07/2025** for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **11/07/2025** at New Delhi, by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Montfort School located at Ashok Vihar, Phase-1, Delhi-110052.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in